

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF WHITLEY COUNTY)	
WATER DISTRICT #1 FOR A DEVIATION)	
FROM THE REQUIREMENTS OF 807 KAR)	CASE NO. 10347
5:066, SECTION 5(4) REGARDING WATER)	
STORAGE)	

O R D E R

By letter received August 8, 1988, Whitley County Water District #1 ("Whitley") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a water utility to provide water storage to insure 1 day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. Whitley's current storage capacity consists of one 26,000-gallon standpipe located in Emlyn, Kentucky.
2. Whitley's average daily usage for calendar year 1987 was 196,170 gallons.
3. Whitley is not currently in compliance with Commission Regulation 807 KAR 5:066, Section 5(4), and cannot comply with that regulation in the immediate future. However, all of Whitley's suppliers have sufficient capacity to provide Whitley's needs.
4. Whitley has applied with various funding agencies for financial assistance to improve its system, including the addition of storage capacity to meet the Commission's regulations.

5. Because of the time needed to plan, finance, and implement a program to increase its water storage facilities and make improvements to its water system, Whitley should be granted a deviation from 807 KAR 5:066, Section 5(4), until July 1, 1992 to bring it within compliance of the Commission's water storage requirements.


IT IS THEREFORE ORDERED that:

1. Whitley be and it hereby is granted a deviation from 807 KAR 5:066, Section 5(4), until July 1, 1992.

2. Whitley shall take all necessary actions to bring its system within compliance of the Commission regulations prior to the expiration date of the deviation herein granted.

Done at Frankfort, Kentucky, this 24th day of January, 1989.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director